

# TABLE OF CONTENTS

---

## Introduction

What is DOE-2?	4
About This Manual	4
Other Documentation	5
What Does a DOE-2 Run Look Like?	7
Sample Input	7
Sample Output	12
Structure of DOE-2	18
Uses for DOE-2	20
How Has DOE-2 Been Validated?	20
Weather Files	21
Program-Related Software and Services	21

## Building Description Language (BDL)

BDL Instructions	1. 1
Terminator	1. 1
Comments	1. 1
INPUT Command	1. 1
END Command	1. 1
COMPUTE Command	1. 2
Keywords	1. 2
U-Names and Referenced Commands	1. 2
Choosing U-Names	1. 3
LIKE Keyword	1. 3
Subcommands	1. 4
Building Description	1. 4
Internal Zoning	1. 4
Use of Comments	1. 5
Alternative Runs	1. 5
Schedules	1. 6
Flexibility of Input Format	1. 6
What Does a DOE-2 Run Look Like?	1. 9
Sample Input	1. 9
Sample Output	1.13

## LOADS

Introduction	2. 1
LOADS Input Instructions	2. 2
Limitation on Number of Commands	2. 2
Description of LOADS Input Instructions	2. 2

## SYSTEMS

Introduction	3. 1
General Discussion of Systems	3. 1
Variable Air Temperature Systems (Constant Volume) (SZRH, PSZ)	3. 2
Reheat Systems (Constant Volume) (RHFS)	3. 3
Air Mixing Systems (Constant Volume) (DDS, MZS, PMZS)	3. 4
Variable Air Volume Systems (Constant Temperature) (VAVS, PVAVS)	3. 5
Hybrid Systems	3. 6

Other System Types in DOE-2 .....	3. 6
Specific HVAC Distribution Systems.....	3. 7
Single Zone Fan System (SZRH) .....	3.10
Constant-Volume Reheat Fan System (RHFS).....	3.13
Multizone Fan System (MZS) .....	3.16
Dual-Duct Fan System (DDS) .....	3.19
Variable-Volume Fan System (VAVS) .....	3.23
Powered Induction Unit (PIU) .....	3.26
Two-Pipe Fan Coil System (TPFC).....	3.32
Four-Pipe Fan Coil System (FPFC).....	3.35
Residential System (RESYS).....	3.38
with DX Cooling and Heating Coil .....	3.38
with Heat Pump .....	3.39
Packaged Single Zone Air Conditioner System with Options (PSZ) .....	3.42
Packaged Multizone Fan System (PMZS).....	3.45
Packaged Variable-Air-Volume System (PVAVS).....	3.48
Packaged Terminal Air Conditioner (PTAC).....	3.51
with DX Cooling and Electric Resistance Heating .....	3.51
with Air-to-Air Heat Pump .....	3.52
Packaged Total Gas Solid Desiccant System (PTGSD).....	3.55
Unit Heater (UHT).....	3.59
Unit Ventilator (UVT) .....	3.61
Description of SYSTEMS Input Instructions .....	3.63
Limitation on the Number of Commands .....	3.63
Reset Schedule Instructions .....	3.64
<b>PLANT</b>	
Introduction .....	4. 1
Suggested Sequence of PLANT Program Input.....	4. 1
Description of ELEC-STM-BOILER.....	4. 2
Description of STM-BOILER .....	4. 2
Description of HW-BOILER .....	4. 2
Description of ELEC-HW-BOILER.....	4. 3
Description of ABSOR1-CHLR.....	4. 3
Description of ABSOR2-CHLR.....	4. 4
Description of ABSORG-CHLR.....	4. 4
Description of HERM-CENT-CHLR.....	4. 4
Description of HERM-REC-CHLR .....	4. 5
Description of DBUN-CHLR .....	4. 5
Description of ENG-CHLR .....	4. 5
Description of COOLING-TWR.....	4. 6
Description of DHW-HEATER and ELEC-HEATER .....	4. 6
Description of PLANT Input Instructions.....	4. 7
Limitation on the Number of Commands .....	4. 7
Chillers.....	4.11
Towers .....	4.12
Boilers .....	4.13
Domestic Hot-Water Heaters .....	4.13
Pumps.....	4.13

## **ECONOMICS**

Introduction .....	5. 1
Example ECONOMICS Input .....	5. 1
Description of ECONOMICS Input Instructions.....	5. 2
Examples of BLOCK-CHARGES .....	5. 9
Yearly Rate.....	5. 9
Seasonal Rate .....	5. 9
Time of Use Rate.....	5.11
Examples of Electricity Tariffs .....	5.16
Basic Tariff .....	5.16
Simple Block Tariff.....	5.16
Seasonal Block Tariff.....	5.17
Demand Charges .....	5.18
Time of Use and Seasonal Demand Charges.....	5.18

## **APPENDIX A Additional Capabilities of DOE-2**

## **APPENDIX B Example of Input and Output**

## **APPENDIX C Basic Reports**

## **APPENDIX D DOE-2 Materials Library**

## **APPENDIX E List of Basic Commands and Keywords**

An alphabetical list of commands and keywords found in this manual

## **APPENDIX F Basic BDL Summary**

The Building Description Language (BDL) Summary lists defaults, limits, and abbreviations for all commands and keywords found in this manual

### What Is DOE-2?

DOE-2 is an up-to-date, unbiased, well-documented public-domain computer program for building energy analysis. DOE-2 predicts the hourly energy use and energy cost of a building given hourly weather information and a description of the building and its HVAC equipment and utility rate structure. DOE-2 is a portable FORTRAN program that can be used on a large variety of computers, including PC's. Using DOE-2, designers can determine the choice of building parameters that improve energy efficiency while maintaining thermal comfort. The purpose of DOE-2 is to *aid* in the analysis of energy usage in buildings; it is *not* intended to be the sole source of information relied upon for the design of buildings. The judgment and experience of the architect/engineer still remain the most important elements of building design.

### About This Manual

During the 15 years that DOE-2 has been in existence, it has grown to three times its original size due to the addition of new capabilities. As a result, using the program can be difficult not only for the novice but also for the experienced user.

The enormous number of input and output variables from which you can choose is only part of the problem. Up until now there has been no attempt to give you guidance as to what is considered "basic" and what might be termed "finesse". Learning to use DOE-2 is analogous to learning a card game: first you learn how to bid, then to follow suit, then to trump. It is only after the "basic" rules have been mastered that the idea of a "finesse" can enter the game. This manual is aimed at introducing you to the basic rules of DOE-2.

*DOE-2 Basics* covers approximately 80% of normal simulation applications, yet requires you to be familiar with only 25% of the input variables available in the program. These variables have been chosen from our long experience of assisting the most experienced users prepare their inputs.

There is a real danger in preparing a manual with a limited set of variables because so many useful features of the program are left out. To compensate for this, we have provided, in Appendix A, a directory of the more complex features of DOE-2.

## Other Documentation

In addition to this *DOE-2 Basics*, there are six other pieces of documentation:

- *Reference Manual (2.1A)*
  - detailed instructions on how to use all features of Version 2.1A of the program
- *Supplement (2.1E)*
  - a companion volume to the *Reference Manual (2.1A)*, it contains detailed discussions and instructions for using the enhancements introduced into subsequent versions of the program
- *BDL Summary (2.1E)*
  - summarizes all input commands and keywords
  - lists defaults, limits, abbreviations
- *Sample Run Book (2.1E)*
  - shows input and output for simple and complex buildings and systems
  - illustrates most program features
  - a complete set of sample inputs and outputs is available on the mainframe DOE-2 tape for you to examine, run, and/or edit; a reduced set of samples is distributed on diskette with the PC versions of DOE-2.
- *Engineers Manual (2.1A)*
  - describes engineering and mathematical basis of program calculations
  - lists sources of algorithms
- *User News*
  - published quarterly
  - distributed free of charge
  - features articles on the effective use of DOE-2
  - lists program problems and bug fixes
  - provides a directory of DOE-2 related software products

Any program user may receive the *User News* free of charge. To be put on the distribution list, please write the Simulation Research Group, Bldg. 90 - Room 3147, Lawrence Berkeley Laboratory, Berkeley, CA 94720.

DOE-2 manuals are available from the National Technical Information Service, 5285 Port Royal Road, Springfield, VA 22161; tel. (703) 487-4650, Fax (703) 321-8547. Contact NTIS for price and delivery information.


<u>Title of Document</u> <u>(version of DOE-2)</u>	<u>NTIS Order Number</u>
<i>Reference Manual (2.1A)</i>	LBL-8706, Rev.2
<i>Supplement (2.1E)</i>	*
<i>DOE-2 Basics (2.1E)</i>	*
<i>BDL Summary (2.1E)</i>	*
<i>Sample Run Book (2.1E)</i>	*
<i>Engineers Manual (2.1A)</i>	DE-830-04575

\* At the time this manual went to press, NTIS reference numbers had not yet been assigned. Please call Kathy Ellington at (510) 486-5711, or fax to (510) 486-4089, for reference numbers.

### What does a DOE-2 run look like?

Following are the input (complete with a system, plant, and energy rate) and selected output reports for the single zone building shown below. (A more detailed version of this building, with five zones and a plenum, is shown in Appendix B.)

BM034



**Figure 1.1:** Simple Structure — Single Zone Building. LEFT-1, FRONT-1, etc. are user-defined names.



## Sample Input

INPUT LOADS ..

TITLE LINE-1 \*SIMPLE EXAMPLE FOR DOE-2 BASICS\* ..

RUN-PERIOD JAN 1 1974 THRU DEC 31 1974 ..

ABORT ERRORS ..

DIAGNOSTIC WARNINGS ..

LOADS-REPORT SUMMARY = (LS-C) ..

### \$ CHICAGO LOCATION

BUILDING-LOCATION LATITUDE = 42.0 LONGITUDE = 88.0  
ALTITUDE = 610 TIME-ZONE = 6  
AZIMUTH = 0 ..

### \$ CONSTRUCTIONS AND GLASS TYPES

WA-1-2 -LAYERS MATERIAL = (WD01,PW03,IN02,GP01) ..

RB-1-1 -LAYERS MATERIAL = (RG01,BR01,IN22,WD01)  
INSIDE-FILM-RES = .76 ..

ROOF-1 -CONSTRUCTION LAYERS = RB-1-1 ..

WALL-1 -CONSTRUCTION LAYERS = WA-1-2 ..

FLOOR-1 -CONSTRUCTION U-VALUE = .05 ..

D1 -CONSTRUCTION U-VALUE = .5 ..

WINDOW-1 -GLASS-TYPE SHADING-COEF = .9 PANES = 2 ..

G-DOOR -GLASS-TYPE SHADING-COEF = .8 PANES = 1 ..

### \$ OCCUPANCY SCHEDULE

OCCUPY-1 -SCHEDULE THRU DEC 31  
(MON,FRI) (1,8) (0)  
(9,11) (1)  
(12,14) (.8,.4,.8)  
(15,18) (1)  
(19,21) (.5,.1,.1)  
(22,24) (0)  
(WEH) (1,24) (0) ..

### \$ LIGHTING SCHEDULE

LIGHTS-1 -SCHEDULE THRU DEC 31  
(MON,FRI) (1,8) (0.05)  
(9,14) (.9,.95,1,.95,.8,.9)  
(15,18) (1)  
(19,21) (.6,.2,.2)  
(22,24) (0.05)  
(WEH) (1,24) (.05) ..



# \$ OFFICE EQUIPMENT SCHEDULE

EQUIP-1	-SCHEDULE	THRU DEC 31
		(MON,FRI) (1,8) (.02)
		(9,14) (.8)
		(15,20) (.8,.7,.5,.5,.3,.3)
		(21,24) (.02)
	(WEH)	(1,24) (.02) ..

# \$ INFILTRATION SCHEDULE

INFIL-1	-SCHEDULE	THRU MAR 31 (ALL) (1,24) (1)
		THRU OCT 31 (ALL) (1,24) (0)
		THRU DEC 31 (ALL) (1,24) (1) ..

# \$ SPACE DEFINITION

OFFICE-ENV	-SPACE-CONDITIONS	PEOPLE-SCHEDULE = OCCUPY-1
		LIGHTING-SCHEDULE = LIGHTS-1
		EQUIP-SCHEDULE = EQUIP-1
		LIGHTING-TYPE = REC-FLUOR-RV
		LIGHTING-W/SQFT = 1.5
		EQUIPMENT-W/SQFT = 1
		AREA/PERSON = 110
		PEOPLE-HEAT-GAIN = 450
		FLOOR-WEIGHT = 70
		INF-METHOD = AIR-CHANGE
		INF-SCHEDULE = INFIL-1
		AIR-CHANGES/HR = .6 ..

OFFICE	-SPACE	SPACE-CONDITIONS = OFFICE-ENV
		AREA = 5000 VOLUME = 40000 ..

# \$ WALLS, WINDOWS, AND DOORS

FRONT-1	-EXTERIOR-WALL	HEIGHT = 8	WIDTH = 100
		AZIMUTH=180	CONSTRUCTION = WALL-1 ..
WF-1	-WINDOW	WIDTH = 45	HEIGHT = 4
		GLASS-TYPE = WINDOW-1 ..	
DF-1	-WINDOW	WIDTH = 8	HEIGHT = 7
		GLASS-TYPE = G-DOOR .. \$ GLASS DOOR	
RIGHT-1	-EXTERIOR-WALL	HEIGHT = 8	WIDTH = 50
		AZIMUTH = 90	CONSTRUCTION = WALL-1 ..
WR-1	-WINDOW	LIKE WF-1	WIDTH = 25 ..
BACK-1	-EXTERIOR-WALL	HEIGHT = 8	WIDTH = 100
		AZIMUTH = 0	CONSTRUCTION = WALL-1 ..

WB-1	-WINDOW	LIKE WF-1	WIDTH = 45 ..
DB-1	-DOOR	WIDTH = 8	HEIGHT = 7
		CONSTRUCTION = D1 ..	\$ WOOD DOOR

---

LEFT-1	-EXTERIOR-WALL	HEIGHT = 8	WIDTH = 50
		AZIMUTH = 270	CONSTRUCTION = WALL-1 ..
WL-1	-WINDOW	LIKE WF-1	WIDTH = 25 ..
TOP-1	-ROOF	HEIGHT = 50	WIDTH = 100
		AZIMUTH = 180	CONSTRUCTION = ROOF-1 ..
BOTTOM-1	-UNDERGROUND-FLOOR	AREA = 5000	
		CONSTRUCTION = FLOOR-1 ..	

END ..  
 COMPUTE LOADS ..

# INPUT SYSTEMS ..

FANS-ON	-SCHEDULE	THRU DEC 31 (MON,FRI) (1,7) (0) (8,18) (1) (19,24) (0) (WEH) (1,24) (0) ..
COOLSETPT	-SCHEDULE	THRU DEC 31 (MON,FRI) (1,7) (99) (8,18) (76) (19,24) (99) (WEH) (1,24) (99) ..
HEATSETPT	-SCHEDULE	THRU DEC 31 (MON,FRI) (1,7) (55) (8,18) (72) (19,24) (55) (WEH) (1,24) (55) ..
DHW	-SCHEDULE	THRU DEC 31 (MON,FRI) (1,7) (0) (8,18) (1) (19,24) (0) (WEH) (1,24) (0) ..
OFFICE	-ZONE	DESIGN-HEAT-T = 72 DESIGN-COOL-T = 74 HEAT-TEMP-SCH = HEATSETPT COOL-TEMP-SCH = COOLSETPT OA-CFM/PER = 20 ..
AC-SYST	-SYSTEM	SYSTEM-TYPE = SZRH MAX-SUPPLY-T = 110 MIN-SUPPLY-T = 55 NIGHT-CYCLE-CTRL = CYCLE-ON-FIRST FAN-SCHEDULE = FANS-ON DRYBULB-LIMIT = 68 OA-CONTROL = TEMP ZONE-NAMES = (OFFICE) ..